



## NRC Regulations for Seismic Analysis and Design Applied to San Onofre Nuclear Generating Station

Christie Hale  
Megan Williams

1



## Overview

1. NRC History and Overview
2. Regulations for Seismic Hazards
3. San Onofre Geologic Siting Criteria and Seismic Design
4. NRC Post-Fukushima Actions

2



## 1. NRC History and Overview

3



## NRC History


- Atomic Energy Commission
  - Atomic Energy Act of 1946
- Nuclear Regulatory Commission
  - Energy Reorganization Act of 1974



4



## Power Plant and Regional Office Locations



5



## How we Regulate



6

## 2. Regulations for Seismic Design

## Applicable Regulations (pre-1997)


- **10 Code of Federal Regulations 100 Appendix A** Seismic and Geologic Siting Criteria for Nuclear Power Plants
  - Required geologic and seismic investigations
  - Procedures for determining design basis ground motions
- **10 Code of Federal Regulations 50 Appendix A Criterion 2** Design Bases for Protection Against Natural Phenomena
  - Structures, systems, and components shall be designed to withstand the effects of natural phenomena without loss of capability to perform their safety function

## Applicable Regulations (pre-1997)

### Design Bases Earthquakes (ground motions)

1. Safe Shutdown Earthquake (SSE)
  - based upon an evaluation of the maximum earthquake potential considering the regional and local geology and seismology
2. Operating Basis Earthquake (OBE)
  - could reasonably be expected to affect the plant site during the operating life of the plant

## Determination of the Safe Shutdown Earthquake




## Regulatory Guidance

### Regulatory Guide 1.60 (1973)

Design Response Spectra for Seismic Design of Nuclear Power Plants

- Newmark method
- 14 strong motion recordings
- Anchored to SSE acceleration



## Changes to Regulations

- In the 80's probabilistic seismic hazard analysis began replacing deterministic approach
- NRC Commission Policy Statement on Severe Accidents in 1985 recognized valuable insights from probabilistic risk assessment (PRAs)
- Individual Plant Examination for External Events (IPEEE) program undertaken in the 90s



## Applicable Regulations (post-1997)

- **10 CFR 100.23** Geologic and Seismic Siting Criteria
- **10 CFR 50 Appendix S** Earthquake Engineering Criteria for Nuclear Power Plants
  - uncertainties must be addressed through an appropriate analysis, such as a probabilistic seismic hazard analysis

13



## Reassessment of Existing Plants

- When new hazard significant information comes available, the possible impact to safety of existing plants is reviewed by NRC staff
- Generic Issue program is the current program for assessment of new information



## 3. San Onofre Geologic Siting Criteria and Seismic Design

15



## San Onofre Nuclear Generating Station (SONGS)



SCE

16



## SONGS Basics

- **Operator:** Southern California Edison
- **Type:** Pressurized Water Reactor
- **Design:** Combustion Engineering
- **Architect:** Bechtel Power Corporation
- **Power:** 2200 Mw




SCE

17



## SONGS Timeline



18




## Final Safety Analysis Report (FSAR)


- The principal document upon which the NRC bases its safety evaluation supporting the issuance of a license
- Describes the facility
- Presents the design bases and the limits on plant operation
- Provides a safety analysis of the structures, systems and components



## Properties of Materials Underlying Site



## SONGS Past Earthquakes




- Plot of Instrumental Epicenters M5.0 and greater, 200-mile Radius
- Compiled from CalTech Catalog, 1932-1980

SONGS UFSAR Figure 2.5-20

21



## SONGS Significant Faults



Annotated version of SONGS UFSAR Figure 2.5-26

22



## SONGS Significant Faults

| Fault                            | Length (km) | Nearest Approach to Site (km) | Largest Historical Magnitude | Maximum Theoretical Magnitude | Maximum Site Bedrock Acceleration (g) |
|----------------------------------|-------------|-------------------------------|------------------------------|-------------------------------|---------------------------------------|
| San Andreas                      | 965         | 92                            | 8+                           | 8+                            | 0.2                                   |
| San Jacinto                      | 272         | 69                            | 6.8                          | 8                             | 0.27                                  |
| Whittier-Elsinore                | 233         | 37                            | 5.1                          | 7.75                          | 0.32                                  |
| Hypothesized Zone of Deformation | 240         | 8                             | 6.3*                         | 7                             | SSE = 0.67<br>OBE = 0.33              |
| Palos Verdes                     | 96          | 18                            | None                         | 7                             | 0.45                                  |


Simplified version of SONGS UFSAR Table 2.5-9

23




## SONGS Design Response Spectra

- Safe Shutdown Earthquake (SSE)
- Horizontal



24



**USNRC** **SONGS Damping Ratios**

- (per Regulatory Guide 1.61)

DAMPING RATIOS USED IN ANALYSIS OF CATEGORY I STRUCTURES, SYSTEMS, AND COMPONENTS

| Item  | Maximum Damping Ratio (Percent of Critical) |                         |
|---|---|-------------------------|
|   | Operational Basis Earthquake                | Design Basis Earthquake |
| Equipment and large diameter piping systems, pipe diameter greater than 12 inches | 2   | 3                       |
| Small diameter piping systems, diameter less than or equal to 12 inches           | 1   | 2                       |
| Welded steel structures   | 2   | 4                       |
| Bolted steel structures   | 4   | 7                       |
| Prestressed concrete structures   | 2   | 5                       |
| Reinforced concrete structures  | 4   | 7                       |

SONGS UFSAR Table 3.7-22

26

**USNRC** **SONGS Seismic Design Classification**

Seismic Category I  
Those structures, components, and systems designed to remain functional if a safe shutdown earthquake ground motion occurs

Seismic Category II  
Those structures, components, and systems whose limited damage could interrupt generation of power.

Seismic Category III  
Those structures, components, and systems whose failure could inconvenience normal plant operation

SONGS UFSAR Section 3.2 27

**USNRC** **SONGS Design Load Combinations**

Example: containment

Operating Conditions  
 $D + L + T_o + F$

Accident Conditions  
 $D + F + T_A + H_A + R + E'$

D = dead load  
L = live load  
 $T_o$  = thermal load  
F = prestress load

$T_A$  = abnormal thermal loads  
 $H_A$  = abnormal pipe expansion  
R = pipe rupture and miscellaneous missile loads  
 $E'$  = design basis earthquake load

SONGS UFSAR Section 3.8 28


**USNRC** **Seismic Qualification of Equipment**

Demonstrates equipment will function during and after an earthquake

Testing/Analysis

- Shake Tables
- Simulates inservice conditions
- Mathematical modeling to simulate operating capability

29



**USNRC** **Pictures**

Yee, SCE

31

**USNRC** **Pictures**

Hale, NRC

32

**USNRC** **Pictures**

Pipe Support

Pipe Whip Restraint

Yee, SCE

33

**USNRC**

**4. NRC Post-Fukushima Actions**

34

**USNRC** **Fukushima Dai-ichi Accident**

35

**USNRC** **Fukushima Dai-ichi Accident**

March 11, 2011 - Great Tohoku Earthquake/tsunami  
 M9, 45 feet waves; 6 nuclear power reactors extensively damaged  
 July 12, 2011 – Task force issued report  
 No imminent danger to continued operations in U.S.  
 12 Recommendations to enhance safety and emergency preparedness

- 1.
2. **#2. Reevaluate seismic and flooding hazard under present-day methodology and guidance**
- 3.
- 4.
- 5.
- 6.

NRC 36

**USNRC**  
NRC Actions

March 12, 2012 – 50.54 (f) Letters Issued

- First regulatory requirements for 104 nuclear power plants
- Mandatory response to five attachments

Recommendation 2 : *Reevaluate and upgrade design-basis seismic and flooding protections of Structures, Systems, and Components*

- 2.1 Hazard Evaluation
- 2.2 Update every 10 years
- 2.3 Walkdowns

37

**USNRC**  
NRC Actions

Recommendation 2.1 Hazard Evaluation: Seismic

Perform a reevaluation of seismic hazards at their site using present-day requirements

- Recommends Senior Seismic Hazard Analysis Committee (SSHAC) process
- Ground Motion Response Spectrum using a probabilistic approach

RG 1.208

•Compare reevaluated seismic hazard and current design basis and results will be:

- No further risk
- Seismic risk assessment
  - Probabilistic risk assessment (SPRA)
  - Margin assessment (SMA)

Staff approved methods

38

**USNRC**  
NRC Actions

Recommendation 2.1 Hazard Evaluation: Seismic

SSHAC Objective:

*Create reproducible, stable estimates of probabilistic seismic hazard at a site (greater regulatory assurance)*

- Evaluation – considering the data, models, and methods of the larger technical community
- Integration – building models that represent the center, body, and range of technically defensible interpretations

39

**USNRC**  
NRC Actions

Recommendation 2.1 Hazard Evaluation: Seismic

**SSHAC - Series of 3 workshops**

- 1<sup>st</sup> Significant Issues and Available Data
- 2<sup>nd</sup> Alternative Interpretations
- 3<sup>rd</sup> Feedback
- Peer Review

40

**USNRC**  
NRC Actions

Recommendation 2.3 Walkdowns: Seismic

*Identify and address vulnerabilities until longer term actions completed*

**Focus on degraded, nonconforming, or unanalyzed conditions**

- Electric Power Research Institute (EPRI) guidance
- Reports due in 180 days (Nov 2012)
- Temporary Instruction required Resident Inspectors to accompany licensee team and conduct independent review

41

**USNRC**  
NRC Actions

Recommendation 2.3 Walkdowns: Seismic

Key Personnel & Seismic Walkdown Equipment List

Not Added to SWEL 1

NRC RFI 50.54(f)

42



## NRC Actions

### Recommendation 2.3 Walkdowns: Seismic

#### Potential Issues:

1. Go through licensing basis evaluation
2. If not easily dispositioned, added to Corrective Action Program
3. All open items at time of reporting go into CAP



Williams, NRC



43



## Contact the NRC

[www.nrc.gov](http://www.nrc.gov)

[christie.hale@nrc.gov](mailto:christie.hale@nrc.gov)

[megan.williams@nrc.gov](mailto:megan.williams@nrc.gov)

44



## Thank You

45



## References

1. SCE, San Onofre Nuclear Generating Station, Units 2 & 3, Updated Final Safety Analysis Report (UFSAR)
2. U.S. NRC, "Design Response Spectra for Seismic Design of Nuclear Power Plants," Regulatory Guide 1.60, ADAMS Accession No. ML003740207, Washington, DC, December 1973.
3. U.S. NRC, "Damping Values for Seismic Design of Nuclear Power Plants," Regulatory Guide 1.61, ADAMS Accession No. ML003740213, Washington, DC, October 1973.
4. U.S. NRC, "A Performance-Based Approach to Define the Site-Specific Earthquake Ground Motion," Regulatory Guide 1.208, ADAMS Accession No. ML070310619, Washington, DC, March 2007.

46



## References

5. U.S. NRC, "Recommendations for Probabilistic Seismic Hazard Analysis: Guidance on Uncertainty and Use of Experts," NUREG/CR-6372, ADAMS Accession No. ML080090003 and ML080090004, Washington, DC, 1997.
6. U.S. NRC, "Practical Implementation Guidelines for SSHAC Level 3 and 4 Hazard Studies," NUREG-2117, Rev. 1, ADAMS Accession No. ML12118A445, Washington, DC, 2012.
7. U.S. NRC, "Request for Information Pursuant to Title 10 of the Code of Federal Regulations 50.54(f) Regarding Recommendations 2.1, 2.3, and 9.3, of the Near-Term Task Force Review of Insights from the Fukushima Dai-ichi Accident," ADAMS Accession No. ML12056A046, Washington, DC, 2012.

47